

KN2/KN4/rAy LonWorks Configuration

Revision History

Version 2.31 (3/7/2017)

Fixed an issue with reading/writing negative values for nviOARLoAirTemp.

Version 2.30 (12/08/2011)

Requires control firmware version 2.70 or greater.

- 1) Added Boiler##_LocalOverride.
- 2) Added Read/Write DHW Setpoint
- 3) Added Boiler Status4 Flags for the Master/Boiler 01 and all Members.
- 4) Added Boiler DHW Temperatures for the Master/Boiler 01 and all Members.
- 5) Added Boiler Modulation for the Master/Boiler 01 and all Members.
- 6) Added OperatingSetpoint for the Master/Boiler 01.

Version 2.23 (6/6/2011)

- 1) Fixed a bug with Runtime and Cycles. Needed to swap upper and lower 16-bit words.
- 2) Added notes to output variable section (nvo) that describes how to modify the configuration to work with Trane controls that require implicit addressing with update notifications.

Version 2.22

Skipped to stay in sync with other products

Version 2.21

Added Modbus Poll Delay = 300ms to limit polling rate to the speed that our control can handle.

Version 2.20

Added (published) Boiler Supply and Return Temperature datapoints.