

# KNLSM (KN2/KN4/rAy) Series Boiler Modbus Register Revision History

---

## Version 1.10 - 7/01/2011 (Requires HeatNet Control Firmware 2.70+)

- 1) Added Read/Write DHW Setpoint
- 2) Updated description of Setpoint Timer (a write to any read/write variable now reloads).
- 3) Updated description of System Modulation.
- 4) Added Boiler Status4 Flags for the Master/Boiler 01 and all Members.
- 5) Added Boiler DHW Temperatures for the Master/Boiler 01 and all Members.
- 6) Added Boiler Modulation for the Master/Boiler 01 and all Members.
- 7) Added OperatingSetpoint for the Master/Boiler 01.
- 8) Changed OARHighWaterTemp range 60 – 190
- 9) Status4Flags DHW Enabled -> DHW Sensor Enabled

PRELIMINARY