

KN Series Boiler - Modbus Register Revision History

Version 2.21 – 10/26/2011

- 1) Added DHW Temperature (Spare 1).

Version 2.20 - 6/08/2011 (Requires HeatNet Control Firmware 3.48+)

- 2) Added Read/Write DHW Setpoint
- 3) Updated description of Setpoint Timer (a write to any read/write variable now reloads).
- 4) Updated description of System Modulation.
- 5) Added Boiler Status4 Flags for the Master/Boiler 01 and all Members.
- 6) Added Boiler DHW Temperatures for the Master/Boiler 01 and all Members.
- 7) Added Boiler Modulation for the Master/Boiler 01 and all Members.
- 8) Added OperatingSetpoint for the Master/Boiler 01.