

FIII Series Boiler - Modbus Register Revision History

Version 2.22 - 10/26/2011

- 1) Added DHW (Spare 1) Temperature.

Version 2.21 - 6/30/2011

- 2) Added Stack Temperature (Spare 2). Currently available in PVC version of firmware only.

Version 2.20 - 6/08/2011 (Requires HeatNet Control Firmware 3.38+)

- 3) Added Read/Write DHW Setpoint .
- 4) Updated description of Setpoint Timer (a write to any read/write variable now reloads).
- 5) Updated description of System Modulation.
- 6) Added Boiler Status4 Flags for the Master/Boiler 01 and all Members.
- 7) Added Boiler DHW Temperatures for the Master/Boiler 01 and all Members.
- 8) Added Boiler Modulation for the Master/Boiler 01 and all Members.
- 9) Added OperatingSetpoint for the Master/Boiler 01.